



CLARK COUNTY DEPARTMENT OF BUILDING

Field Inspection Guideline



SUBJECT: Show Window Receptacles

FIG-E-015

Effective Date: January 5, 2007

Revised: April 04, 2014

Approved By: BAT

Code Chapter: 2011 NEC Sec. 210.62, Definition: Article 100

Page 1 of 1

Interpretation:

The NEC requires receptacle outlets to be installed directly above and within 18 inches of the top of show windows. One Receptacle shall be installed for each 12 ft or major fraction thereof of show window, measured horizontally.

Field Application:

The following guideline shall define when windows are to be considered show windows:

- For facilities with show room windows to be used as a display or advertisement, the facility design documents will be required to indicate this and shall have receptacles installed to comply with NEC 210.62.
- For facilities that have show windows that are not to be used as a display or advertisement, the facility design documents should so note and receptacles will not be required per NEC 210.62.

Revision History:

Reference #	Title	Effective Date	Revised	Reviewed
FIG-E-015	Show Window Receptacles	January 5, 2007		May 23, 2013
FIG-E-015	Show Window Receptacles		April 04, 2014	